

# Office of The Chief Medical Officer, Ghaziabad

Ref.No. DSO/IDSP/2024/3354

Dated:- 21-02-2024

## WATER TEST REPORT

ADDRESS:- ADHARSHEELA GLOBAL SCHOOL, SECTOR-03, VASUNDHARA, GHAZIABAD.

PREVIOUS SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
N/A	N/A	N/A	N/A	N/A

No of sample collected : 01

SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
14-02-2024	RO WATER	DRINKING	1922	Satisfactory

### Test Result

H<sub>2</sub>S Water test kit : Negative (-Ve) after 24-48 hrs incubation


### Comments:-

H<sub>2</sub>S water test kit report - ve reflects that water is free from Coliforms Organism.

### Recommendation:

Given water safe for drinking purpose.

Validity upto one year.



Lab Technician  
IDSP Lab  
Ghaziabad

*Suruchi Saini*  
(Dr. Suruchi Saini)  
Microbiologist IDSP Lab  
Ghaziabad

ADHARSHEELA GLOBAL SCHOOL  
Sec. 3, Vasundhara, Ghaziabad

Manager

*R.K. Gupta*  
(Dr R.K Gupta)  
District Public Health Expert  
District Ghaziabad  
District Public Health Expert  
District Ghaziabad